



Commercial Fire Protection

HYDROSTATIC TEST INTERVAL FOR EXTINGUISHERS

<u>Extinguisher Type</u>	<u>Test Interval (years)</u>
Stored-pressure water, water mist, loaded stream, and/or antifreeze	5
Wetting agent	5
AFFF (aqueous film-forming foam)	5
FFFP (film-forming fluoroprotein foam)	5
Dry chemical with stainless steel shells	5
Carbon dioxide	5
Wet chemical	5
Dry chemical, stored-pressure, with mild steel shells, brazed brass shells, or aluminum shells	12
Dry chemical, cartridge- or cylinder-operated, with mild steel shells	12
Halogenated agents	12
Dry powder, stored-pressure, cartridge- or cylinder-operated, with mild steel shells	12

FREQUENCY (IN YEARS) OF INTERNAL MAINTENANCE AND HYDROSTATIC TESTING OF FIRE EXTINGUISHERS

<u>Type of Extinguisher</u>	<u>Internal Maintenance Interval</u>	<u>Hydrostatic Testing Interval</u>
Dry chemical	6	12
Water, AFFF, FFFP, antifreeze	5	5
Halogenated agent	6	12
Carbon dioxide	5	5