



Commercial Fire Protection

STANDPIPE AND HOSE SYSTEMS

Device	Frequency
<i>Inspection</i>	
Control valves	Weekly / monthly
Pressure regulating devices	Quarterly
Piping	Annually
Hose connections	Annually
Cabinet	Annually
Hose connections	Annually
Hose storage device	Annually
Hose nozzle	Annually and after each use
<i>Test</i>	
Waterflow devices	Quarterly / semiannually
Valve supervisory devices	Semiannually
Supervisory signal devices	Semiannually
Hose storage device	Annually
Hose storage device	5 years / 3 years
Pressure control valve	5 years
Pressure reducing valve	5 years
Hydrostatic test	5 years
Flow test	5 years
Main drain test	Annually
<i>Maintenance</i>	
Hose connections	Annually
Valves	Annually / as needed